

Agenda Item Summary

**1. ACTION REQUESTED/PURPOSE:** Approve award of formal quotation (RFP B&R 2661-SM126) and issuance of a purchase order to Compressed Air Company, Inc. (Comairco), the low price proposer, meeting all specification requirements for two air compressors and related equipment, in an amount of \$114,796.00, plus a not-to-exceed allowance of \$5,000 for field service start-up assistance.

**2. WHAT ACTION ACCOMPLISHES:** Provides the necessary air compressor equipment for the waste to energy expansion project.

**3. MANAGEMENT RECOMMENDATION:** Staff recommends approval of the requested motion.

**4. Departmental Category:** 8 C8J **5. Meeting Date:** 06-28-2005

<b>6. Agenda:</b> <input checked="" type="checkbox"/> Consent <input type="checkbox"/> Administrative <input type="checkbox"/> Appeals <input type="checkbox"/> Public <input type="checkbox"/> Walk-On	<b>7. Requirement/Purpose: (specify)</b> <input type="checkbox"/> Statute <input type="checkbox"/> Ordinance <input checked="" type="checkbox"/> Admin. Code 4-1 <input type="checkbox"/> Other	<b>8. Request Initiated:</b> Commissioner _____ Department <u>Public Works</u> Division <u>Solid Waste</u> By: <u>Lindsey J. Sampson</u> 
--	---	--

**9. Background:** Sealed quotes were received by the County's design engineer, Burns & Roe, on behalf of the Solid Waste Division on April 22, 2005. On that date three (3) responses were received. After review, recommendation was made to award to the low-priced proposer meeting all specification requirements. Note, evaluated pricing includes a factor for energy consumption during normal operation. Although Comairco has a penalty of \$10,198.00, it is still the low priced vendor.. Backup documentation refers to an adder of \$1,225 for an optional performance bond. The Solid Waste Division does not want to make use of this option.

Funds are available in account string: 200923 40102.506540

Attachments: Burns & Roe bid evaluation dated 5/20/2005  
 Tabulation sheet  
 Covanta Comments on the B&R bid evaluation dated 6/3/2005

**10. Review for Scheduling:**

Department Director	Purchasing or Contracts	Human Resources	Other	County Attorney	Budget Services				County Manager/P.W. Director
					Analyst	Risk/	Grants	Mer.	
		NA							

**11. Commission Action:**

- Approved
- Deferred
- Denied
- Other

RECEIVED BY  
 COUNTY ADMIN  
6/15/05  
2:30  
 COUNTY ADMIN  
 FORWARDED TO:  
Admin  
3:30 PM

Rec. by COADM  
 Date: 6/15/05  
 Time: 1:45  
 Forwarded To:  
Admin



May 20, 2005

**LEE COUNTY  
WTE EXPANSION PROJECT  
FORT MYERS, FLORIDA**

**RFP 2661-SM126  
AIR COMPRESSORS**

**BID EVALUATION**

Burns and Roe Enterprises, acting on behalf of Lee County issued Request for Proposal No. 2661-SM 126 "Air Compressors" on March 22, 2005 to the following pre-approved bidders: Atlas Copco; Comairco; Gardner Denver; and Scales. Gardner Denver declined to bid.

On April 22, 2005 bids were received from:

- Atlas Copco proposal #4545/0405/6BMRC3 dated 4/22/05
- Scales Air Compressor proposal dated 4/20/05
- Comairco (Sullair) proposal dated 4/22/05

Bids were opened and recorded on the Proposal Opening Form included here as Attachment A. Attachment B is the Bid Abstract comparing bid prices and adjustments made thereto.

**RECOMMENDATION:**

The recommended award of the contract is to Compressed Air Company (COMAIRCO). Recommended award price is \$114,796 FOB Jobsite, Freight Prepaid and Allowed and excludes cost of Bonds and Sales or Use Tax.

Base Price, as bid	\$103,865
Adjust to comply with Specifications	<u>\$ 10,931.</u>
Recommended Award Price:	<b>\$114,796.</b>

**BID EVALUATION 2661-SM126 "Air Compressors" (cont'd...)**

**COMMERCIAL EVALUATION:**

Two (2) of three (3) bids were reviewed based on bidder's compliance with the Scope of the RFP and Contract terms and conditions and price. Engineering determined

**Atlas Copco's...** After an initial review and questions, engineering determined bid does not meet the specifications, incomplete, and non-competitive. No further consideration or commercial review was conducted.

**Scales Air...** Extensive questions were requested of Scales for equipment to comply with the specifications. As a result, Scales bid was deemed technically unacceptable by engineering. In addition, Scales pricing with adjustments is 29% higher than the low bidder.

**Comairco...**base price was low. Technical adjustments to Comairco's submittal increase bid by \$10,931. This included combination starter/breaker, larger dryer to meet requirements and a third air receiver. Including these adjustments Comairco is approximately 29% low. Power consumption factor of \$10,198 was applied to Comairco's pricing. Comairco offered a Performance/Payment Bond at a \$2,650 additional cost. Field Service rate is \$680 per day plus out of pocket (travel, subsistence) costs. Submittal of approval drawings/documents is 21 days after receipt of order. Delivery is May 15, 2006 consistent with project schedule.

Commercially, Comairco has proposed the following terms:

Payment Terms:      25% - engineering and approved drawings complete  
                                 25% - upon release to manufacture (Feb. 2006)  
                                 50% - delivery at site

Delivery: May 15, 2006

Comairco pricing is valid till June 15, 2005.

Comairco accepts the Services/Goods Purchase Conditions.


LEE COUNTY, FLORIDA  
PROPOSAL OPENING FORM

RFP NUMBER 2661-SM-<sup>126</sup>~~126~~ DATE 4.25.05  
 TITLE Air Compressor TIME 2:30 pm

Bidder	Proposal Date	Date Received	Unevaluated Price	Remarks
1 Scales Air	4.20.05	4.21.05	\$ 106,236.-	
2 Comairco (Sullivan)	4.22.05	4.22.05	\$ 103,866.-	
3 Atlas Copco	4.22.05	4.22.05	\$ 156,010.	
6				
7				
8				

OPENED BY: [Signature] 4.25.05  
 WITNESSES: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BID ABSTRACT		AIR COMPRESSORS						
ITEM	QTY	UNIT	DESCRIPTION	1	2	3	4	5
Burns and Roe Enterprises, Inc.								
W/O: 2661 Lee County Expansion Project								
RFP 2661-SM126 Air Compressors								
1	2	ea	Air Compressors:					
			No. 1 w/air dryer & Receiver,					
			Aftercooler, mist eliminator	\$ 64,868	\$ 58,756	\$ 92,315		
			No.2 - Compressor only	\$ 38,868	\$ 43,309	\$ 63,695		
			Total Freight	\$ 2,500	\$ 1,800	included		
			As Bid Total	\$ 106,236	\$ 103,865	\$ 156,010		
			Tech Adjustment - see Tech Eval	\$ 42,290	\$ 10,931	not evaluated		
			Recommended Award Price	\$ 148,526	\$ 114,796	---		
			+33,730		base			
			+29%					
			Power Consumption Cost	0	\$ 10,198	---		
			Total Evaluated Cost	\$ 148,526	\$ 124,994			
			PERFORM./PAYMENT BONDS	\$ 2,650	\$ 1,225	---		
			Sales/Use Tax	none	none			
			Bid Validity	n/a	6/15/2005	n/a		
						not evaluated		
			Drawings Submitted	3-4 wks	21 days	---		
			Jobsite Delivery	5/15/2006	5/15/2006	---		
			PAYMENT TERMS	net 30	Milestones	Milestone		
			F.O.B. Delivered DESTINATION	Ft. Myers	Ft. Myers	Ft. Myers		
			TECHNICALLY ACCEPTABLE	no	yes	no		
AWARD RECOMMENDATION: COMAIRCO								
REASON FOR RECOMMENDATION:								
						PREPARED BY: D'Amico	DATE:	
						REVIEWED BY:		



**TECHNICAL BID EVALUATION**  
**REQUEST FOR PROPOSAL No. 2661-SM-126**  
**AIR COMPRESSORS**

**SUMMARY**

Request for Proposal was sent to four bidders: Garden Denver, Comairco Equipment (Sullair compressors), Scales Air Compressor (Quincy compressors) and Atlas Copco. Garden Denver declined to bid. Proposals from the other three bidders were received and evaluated.

A preliminary evaluation was performed on all proposals received. The preliminary evaluation indicated that the proposals from Comairco and Scales were substantially complete. The proposal from Atlas was incomplete. Based on the preliminary evaluation, a list of questions/comments was sent to each Bidder. The equipment initially proposed by Atlas was considerably oversized. Therefore, as a result of this, and the fact that the proposal was incomplete, Atlas needed to re-bid the entire proposal.

The full evaluation indicated that the equipment offered by Comairco was technically acceptable, and the one from Scales and Atlas was not acceptable.

**TECHNICAL DISCUSSION**

**GENERAL**

After receiving the proposals it was concluded between Covanta and BREI that a third "wet" air receiver upstream of the dryer would be advantageous for the installation. This approach provides additional surge capacity and assures a more steady flow through the dryer circuit. Therefore, bidders were requested to provide optional price for a third air receiver, identical to the two initially included in the proposal. The third receiver is included as a recommended option in this evaluation.

The compressors will be installed inside the turbine building. The specification, under project specific requirement 3.8, indicates that the source of air is from outside the turbine building. This requires ducting the outside air up to the compressors' inlet. This requirement was discussed with Covanta, and it was concluded that since the turbine building is a relatively clean area, the compressors could take suction directly from inside the building without the need of any ductwork. Refer to D. Anacker e-mail of 4/29/05 for more details. Therefore, the project specific requirement 3.8 was not taken into consideration in this evaluation, and the same should be deleted from the specification.

Similarly, since the compressors would be installed in the turbine building, Covanta indicated that, unless required for sound attenuation purposes, a compressor enclosure would not be required. BREI agrees with this approach. Comairco and Scales were requested to quote an option for the removal of the enclosure if not needed to meet

noise limits. The two bidders indicated that the enclosure was required to meet sound levels.

Both, Comairco and Scales, proposed the compressors with inlet valve modulation for flow control capability. The equipment from Atlas did not provide this feature; it would operate in a load/unload mode only.

#### Comairco Proposal:

The original proposal required some clarifications. With the additional clarifications, it was found that the equipment proposed by Comairco included some exceptions. After evaluating all exceptions, it is BREI's recommendation that they be accepted. For details on the exceptions refer to Attachment 2.

A combination motor starter/breaker, as required per the specification, was not included in the original proposal. It was offered subsequently as an option (considered as a price adjustment in Attachment 4).

The original mist eliminator proposed did not meet efficiency requirements. Subsequently, Comairco offered a Hankinson mist eliminator, at no extra cost, that meets the efficiency requirements. Similarly, the original dryer did not meet capacity requirements and Comairco offered a larger one, at an extra cost, to meet capacity. The mist eliminator is identical to the one proposed by Scales.

The cooling water flow required was slightly larger than the one required by Scales (66 gpm vs. 50 gpm). However, it shall be pointed out that, with 50 gpm, Scales does not meet specification requirements and BREI calculated that Scales' compressors would need approx. 75 gpm to meet specification requirements. In any case, this differential in water flow is negligible from the operating cost point of view; therefore, it has not been included as an evaluated cost in this evaluation.

The combined power consumption of compressor motor plus electric heater is 114 Kw.

#### Scales Proposal:

The original proposal required some clarifications. With the additional clarifications, it was found that the equipment proposed by Scales included some exceptions. After evaluating all exceptions, BREI deemed two of them as not acceptable. For details on all the exceptions refer to Attachment 2.

The original compressor proposed did not meet capacity requirements. Subsequently, Scales proposed a larger compressor that did not meet capacity either. However, it was approximately 2% short in capacity (492 scfm proposed vs. 500 scfm specified). BREI did not consider this deficiency a reason to disqualify this bidder.

The originally proposed dryer did not meet capacity requirements (600 scfm @ 110 psig and 120 °F). Scales was notified of this shortcoming. Subsequently, Scales proposed a larger dryer, at an additional cost, that still did not meet capacity. The larger dryer had a capacity of approximately 450 scfm at design conditions.

The design of the compressor's coolers is such that the cooling water outlet temperature is 125 °F. Per the specification, the maximum allowable temperature is 115 °F. If the water flow were to be increased to maintain the outlet temperature below 115 °F, it is BREI's estimate that the pressure drop throughout the coolers would exceed the maximum 10 psi specified. Consequently, BREI concluded that the coolers are not large enough.

The initial motor proposed by Scales was not from an approved manufacturer as listed in the specification. Subsequently, Scales proposed a different motor, at an additional cost, manufactured by Siemens. This is an approved manufacturer. However, Scales did not submit the corresponding motor data sheet.

Considering the above, the equipment proposed by Scales, was deemed not acceptable.

#### Atlas Copco Proposal:

The initial proposal from Atlas was incomplete and included an oversized compressor. Therefore, Atlas was asked to provide a complete revised proposal based on the correct compressor capacity. A preliminary review of the revised proposal submitted by Atlas revealed that it was still incomplete, filled-in Attachment 2 of SM-126 was never submitted and attachment 2 of SE-211 was submitted blank. The revised proposal included an undersized compressor and the proposed mist eliminator did not meet the maximum oil carry over limit. Further, the quoted price (\$141,665.00) was approximately 25 % higher than the lowest bidder. As a result of this it was decided not to give further consideration to the Atlas proposal and concentrate in the remaining two bidders. Consequently, a full evaluation of the Atlas proposal was not performed, a summary of Atlas' exceptions and resolution was not prepared, and the total adjusted equipment cost shown in Attachment 4 shall be considered approximate.

#### PERFORMANCE EVALUATION

The proposals submitted indicate that the proposed equipment from Comairco would meet the required performance, which includes:

- Minimum air flow capacity at compressor discharge rated pressure of 125 psig
- Air dew point downstream of dryers
- Air pressure at outlet of after-filter
- Mist eliminator efficiency
- Pre-filter and after-filter efficiency
- Compressor's oil/hydrocarbon carryover

The equipment offered by Comairco meets the above with an additional use of power of approximately 2.8 Kw over the equipment offered by Scales (114 Kw vs. 111.2 Kw). This additional power has been taken into consideration as an evaluated cost in the pricing summary.



## **PRICING EVALUATION**

Refer to Attachment 4 – Pricing Summary. Comairco is the lowest bidder for the equipment with the corresponding required options and the BREI's recommended options included. The total adjusted equipment cost of Comairco's equipment with the recommended options is approximately 30% less than the equipment offered by Scales. Comairco is also the bidder with the lowest evaluated cost (19% less than Scales). This difference in price between Comairco and Scales would be larger had Scales been asked to re-bid the equipment to include larger dryer and compressor coolers to meet the specification.

Although not indicated in the specification, the use of a third "wet air" receiver upstream of the dryer has been discussed between Covanta and BREI. The price of this receiver is included as a "recommended option" in Attachment 4.


## **RECOMMENDATION**

The equipment proposed by Comairco, with the required options offered, was found technically acceptable. The equipment proposed by Atlas and Scales was found not acceptable. Although the non-conformance components of the equipment proposed by Scales could be revised to bring the entire package up to specification; considering the current price differential, it was concluded that this exercise was not necessary at this point, unless formal commercial evaluation dictates otherwise.

Comairco is the recommended bidder as the only one with technically acceptable equipment and with the lowest total adjusted equipment cost.

The equipment from Comairco must be purchased with the following required and recommended options:

- One additional air receiver (total 3 receivers. Recommended option)
- Combination starter/breaker (required option with price adjustment)
- Hankinson mist eliminator (required option, no price adjustment)
- Larger dryer (TWP1000. Required option with price adjustment)



**TECHNICAL BID EVALUATION**  
**REQUEST FOR PROPOSAL No. 2661-SM-126 AIR COMPRESSORS**  
**ATTACHMENT 1 – APPLICABLE DOCUMENTS**

Lee County RFP No. 2661-SM126

Burns and Roe Documents:

E-mail form D. D'Amico to Comairco, dated 4/30/05; initial questions/comments  
E-mail form D. D'Amico to Comairco, dated 5/6/05; follow-up questions/comments  
E-mail form D. D'Amico to Comairco, dated 5/10/05; additional questions/comments  
(breaker requirements and dryer size)  
E-mail form D. D'Amico to Comairco, dated 5/16/05, request for revised electrical  
diagram

E-mail form D. D'Amico to Scales, dated 5/2/05; initial questions/comments  
E-mail form D. D'Amico to Scales, dated 5/6/05; follow-up questions/comments  
E-mail form D. D'Amico to Scales, dated 5/10/05; additional questions/comments  
(breaker requirements)

E-mail form D. D'Amico to Atlas, dated 5/2/05; initial questions/comments (request for  
requite

Covanta Documents:

E-mail from D. Anacker to BREI, dated 4/29/05, source of inlet air  
E-mail from D. Anacker to BREI, dated 5/4/05, overall comments to proposals  
E-mail from D. Anacker to BREI, dated 5/4/05, flow control comments  
E-mail from D. Anacker to BREI, dated 5/6/05, comments on revised proposal from Atlas  
E-mail from D. Anacker to BREI, dated 5/6/05, comment on oil/water removal  
requirements

Comairco Documents:

Proposal dated April 22, 2005.  
E-mail to BREI, dated 5/5/05; response to initial BREI's questions/comments  
E-mail to BREI, dated 5/9/05; response to follow-up BREI's questions/comments  
Fax to BREI, dated 5/9/05, motor data sheet  
E-mail to BREI, dated 5/11/05; response to breaker and dryer questions  
Fax to BREI, dated 5/17/05, revised electrical diagram

*E-mail to BREI dated 5/17/05*

Scales Documents:

Proposal dated April 20, 2005  
Fax to BREI, dated 5/4/05; response to initial BREI's questions/comments  
Fax to BREI, dated 5/13/05; response to follow-up BREI's questions/comments

Atlas Copco Documents:

Original Proposal dated April 20, 2005  
Revised Proposal dated May 6, 2005

**TECHNICAL BID EVALUATION**  
**ATTACHMENT 2 - SUMMARY OF TECHNICAL EXCEPTIONS AND CLARIFICATIONS**  
**RFP No. 2661-SM-126 - AIR COMPRESSORS**

BIDDER: COMAIRCO

Technical Exception/Clarification	BREI Response/Resolution
The male rotor speed of proposed compressor is 2100 rpm. The specification requires maximum 1800 rpm.	Sullair air compressors are of proven reliability and should not be disqualified on the ground of exceeding the specified maximum rpm. BRE recommends this exception be accepted.
Coolers proposed are not ASME Code coolers nor have removable tube bundles.	Considering the size of the coolers, ASME Code is not required. Also, for this size coolers BREI considers that the removable tubes does not have to be a must. The entire cooler could be removed, cleaned and reinstalled without major work. BREI recommends this exception be accepted.
Purge air is approx. 7%. The Specification requires maximum 4%.	The 4% is too stringent. Available standard air purge rate for heated dryers is typically 15%, with upgraded models requiring 6%-7%. BRE recommends this exception be accepted.
The mist eliminator would be shipped loose for field installation by Others in the piping between compressor skid and air receiver.	This is an exception taken by all Bidders. The compressor skids are of a compact design and do not have extra room for additional optional equipment. BREI recommends this exception be accepted.
Mist eliminator proposed, Sullair ME600 does not meet efficiency requirements	Exception not acceptable. Subsequently, Comairco offered as an option mist eliminator Hankinson MM3. This eliminator meets efficiency requirements. Therefore, this exception would be resolved by exercising the option.

**TECHNICAL BID EVALUATION**  
**ATTACHMENT 2 - SUMMARY OF TECHNICAL EXCEPTIONS AND CLARIFICATIONS**  
**RFP No. 2661-SM-126 - AIR COMPRESSORS**

**BIDDER: SCALES AIR COMPRESSORS**

Technical Exception/Clarification	BREI Response/Resolution
Coolers are not ASME Code designed or stamped as per SM-126, 2.4.7.	Because the size of the coolers, ASME Code is not required, not available from the Mfr. BREI recommends this exception be accepted.
Coolers have the water in the shell.	The specification requires the water in the tube side. Considering the size of the proposed coolers, BREI recommends this exception be accepted.
The mist eliminator would be shipped loose for field installation by Others in the piping between compressor skid and air receiver.	This is an exception taken by all Bidders. The compressor skids are of a compact design and do not have extra room for additional/optional equipment. BREI recommends this exception be accepted.
Temperature gauges on dryer skid were not included.	Subsequently, Scales offered the gauges as an option. Therefore, this exception would be resolved by exercising the option.
The proposed compressor has a capacity of approximately 492 scfm at 125 psig disch. and 120 oF inlet temp. (max. temp.)	This is the second unit proposed by Scales. The first one had an approx. capacity of 445 scfm, which did not meet spec. requirement. The second unit proposed does not meet capacity (500 scfm) either, however the deficiency is approximately 2%. BREI recommends this exception be accepted.
Purge air is approx. 7%. The Specification requires maximum 4%.	The 4% is too stringent. Available standard air purge rate for heated dryers is typically 15%, with upgraded models requiring 6%-7%. BRE recommends this exception be accepted.
The temperature of CC water return would be 125 degrees F. The Specification requires maximum 115 degrees F.	This exception is not acceptable. The size of the coolers should be increased. With the proposed coolers, to maintain the maximum 115 degrees F. approximately 75 gpm would have to be run throughout the coolers. BREI estimated that this would result in a pressure drop of more than 10 psi, which is the maximum allowed per the Specification.
The inlet air filter is not a two stage type filter.	Scales indicated that the proposed filter, manufactured by Donaldson, is the typical standard heavy duty filter used by Scales with their Quincy compressors. BREI recommends this exception be accepted.
The Capacity of the proposed air dryer is 549 scfm at 110 psig and 120 degrees F. The Specification requires the capacity to be 600 scfm.	Scales originally proposed a dryer with a capacity of approx. 370 scfm at design conditions. As a result of the non-conformance, Scales proposed a larger dryer that still does not meet specification requirements. This exception is not acceptable.

A. PLANT AND INSTRUMENT AIR COMPRESSOR

Compressor Data

Manufacturer

Model

Rated Capacity at 125 psig,  $\frac{ACFM}{SCFM}$

BHP at rated capacity and 125 psig

Male Rotor Speed (rpm)/Tip Speed (ft/sec)

Rotor Construction

Rotor Dia. In.

Critical Speed, rpm

Max. Cont. Speed, rpm

Max. Casing Temp., °F

Materials

Casing

Rotor

Shaft

Radial Bearings: Type

Thrust Bearings: Type

Seals: Type

Flange Connections

Inlet Size/Rating

Inlet Location

Disch. Size/Rating

Disch. Location

COMAIRCO

SULLAIR

LS2005-125HWC

587 ACFM / 500 SCFM

142.9

2100 / 22.4

STEEL

204 mm

N/A

N/A

N/A

CAST IRON

STEEL

STEEL

ROLLERS

TAPERED

DOUBLE LIP

N/A

PACKAGE MTD.

2" NPT

PACKAGE

SCALES

QUINCY

QSI S40

492 SCFM

141

1785

DUSTY IRON

255 MM

3600

1785

N/A

GREY IRON

DUSTY IRON

DUSTY IRON

TAPERED ROLLER

SALEMAN

TRIPLE LIP

2" NPT

IN PACKAGE

2 1/2"

SEE PLANT

REMARKS

① EXCEPTION TAKEN. SEE ATTACHMENT 2 FOR DETAILS.

	COMAIRCO	SCALES
Compling Manufacturer		REX NORD
Type	FLEX	FLEX
Size	N/A	
Lubrication	NONE	N/A
Slide Base	N/A	N/A
Coupling Guard, (yes/no)	YES	YES
Enclosed	YES	YES
Open		NO
Mounting		Foot Mount
Scieplate Compressor		Foot Mount
Driver		Foot Mount
Baseplate Compressor	YES	
Driver	YES	
Foundation Bolts by		
Manufacturer		
Purchaser	X	X
Accessories		
Air Intake Filter	YES	BUNT IFO
Manufacturer	SULLAIR	DONALDSON
Model	OPTIMALAIR	1 Dry Type
Type	Dry	Polyester
Maximum Capacity (SCFM)	1500	900 cfm 3/4"
Oil Cooler		
Type	SHELL + TUBE	1 Shell + Tube

REMARKS

1 EXCEPTION TAKEN. SEE ATTACHMENT 2 FOR DETAILS.

SAT 2/9

	COMAIRCO	SCALES	REMARKS
Dimensions	N/A	4' x 6'	1 TOTAL FOR OIL COOLER & AFTER COOLER.
Weight	N/A	190 #	2 INLET TEMP TO A. COOLER.
ASME Code Req'd	(4) ND	(4) No	3 SEE NOTES (1) & (2). COOLERS ARE IN SERIES, FIRST TO A. COOLER, THEN TO OIL COOLER.
CW Required (gpm)	(5) 354 @ 80°F	(5) 50 GPM	4 EXCEPTION TAKEN. SEE ATTACHMENT 2 FOR DETAILS.
CW Temp. (Inlet)	(5) 80-95	(5) 95°	5 PER COMAIRCO E-MAIL OF 5/10/05.
CW Temp. (Outlet)	(5) 100-110	(5) 125°	
Pressure Drop (CW Side)	(5) 2.5-4.3 PSI	(5) S	
Materials:			
Shell	STEEL	CI	
Tube	Copper	Copper	
Tube Sheet	STEEL	Act	
After cooler			
Dimensions		3' x 5'	
Weight		150 #	
CW Required (gpm)	(5) 25 @ 80°F	(3)	
CW Temp. (Inlet)	(5) 95-80	(3)	
CW Temp. (Outlet)	(5) 110-100	(3)	
Pressure Drop (CW Side)	(5) 1.7 @ ps:		
Materials:			
Shell	STEEL	CI	
Tube	Copper	Copper	
Tube Sheet	STEEL	Act	
Moisture Separators - After cooler			
Manufacturer/Model	DM	Wright Austin	

SMT 3/9



REMARKS

SCALES

COMAIRCO

Included with Cooler	YES	YES	1
Maximum Capacity	1000 scfm	1100 cfm	
Automatic Cond. Trap/Mfr.	YES	Yes - Wylight Austin	
Capacity (lbs/hr)	750 scfm	Enough	
Air Receiver			
Vertical	YES	X	
Horizontal			
Diameter	36"	36"	
Length	96"	9'	
Volume (cu-ft)	400 gal	53 ft <sup>3</sup>	
Max. Working Pressure (psig)	150	150	
Hydrostatic Test Pressure (psig)	225	225	
Relief Valve Size	T.B.D.	1"	
Set Pressure (psig)	150	150 psi	
Drain Size	1"	1"	
Material			
Corrosion Allowance	N/A	None	
Accessories to include 4 1/2" pressure gage, relief valve, drain valve, service valve and inspection openings (yes/no)	YES	YES	
Conditions @:	Capacity - SCFM	Capacity - SCFM	
1st Stage Outlet	500	492 scfm	
A/C Discharge	500	492	
Sep. Discharge	500	492	
Rec. Discharge	500	Opened on Demand	
Dryer Discharge	500	462 cfm	

1 PER COMAIRCO E-MAILS OF 5/18/05 & 5/19/05.  
2 EXCEPTION TAKEN. SEE ATTACHMENT 2 FOR DETAILS.

REMARKS

① PER COMAIRCO E-MAIL OF 5/10/05.

SCALES

COMAIRCO

Temperature - °F

185  
110 95 ~~110~~ CW  
110 ~~110~~ 95  
95 80  
95 80

Pressure - psig

125  
125  
125  
125  
127

Temperature - °F

185°F  
110°  
110°  
Lower - Depends on Ambient  
125°F

Pressure - psia

140  
140  
140  
139  
129

No  
Yes  
Yes - Auto Demand

Compressor Pkg

No  
No  
No  
Yes

Conditions @

1st Stage Outlet  
A/C Discharge  
Sep. Discharge  
Rec. Discharge  
Dryer Discharge

Conditions @:

1st Stage Outlet  
A/C Discharge  
Sep. Discharge  
Rec. Discharge  
Dryer Discharge

Capacity Control

Start Stop  
Continuous Speed  
Dual Control

Piloted by  
Receiver Pressure  
Purchased Inst.

Suction Valve Unloading  
Manual  
Automatic

Accessories to Include:  
Interstage Piping

SAT 5/19

REMARKS

	COMAIRCO	SCALES
Moisture Separator w/traps	<u>YES</u>	<u>yes</u>
After cooler	<u>—</u>	<u>yes</u>
Cooling Water Piping	<u>—</u>	<u>yes</u>
Sight Flow Indicators	<u>—</u>	<u>NO</u>
Solenoid Operated Water Valve to Control Cooling	<u>—</u>	<u>yes</u>
Water to comp, A/C	<u>—</u>	<u>2</u>
Air Intake Filter	<u>—</u>	<u>yes</u>
Dimensions, Weights		
Compressor and Base, lbs.	<u>4500</u>	<u>4500 #</u>
Length, inches	<u>100</u>	<u>102"</u>
Width, inches	<u>60</u>	<u>56"</u>
Height, inches	<u>67</u>	<u>60"</u>
Accessories, lbs	<u>—</u>	<u>6000</u>
Driver, lbs	<u>300</u>	<u>750 #</u>
Erection Weight, lbs	<u>4500</u>	<u>—</u>
Maintenance Weight, lbs	<u>4500</u>	<u>1400 #</u>
Installation		
Indoors	<u>YES</u>	<u>X</u>
Outdoors	<u>NO</u>	<u>—</u>
Motor Starters		
NEMA Size	<u>5</u>	<u>5</u>
Manufacturer	<u>C-H</u>	<u>SIEMENS</u>
Acoustic Enclosure, (yes/no)	<u>IN CONTROL PANEL</u>	<u>yes</u>

SHT 6/9

	COMAIRCO	SCALES	REMARKS
Furnish as packaged; compressor(s), after cooler(s), moisture separator(s), dryer(s), receiver(s) and dryer(s) including piping interconnecting wiring and controls. (yes/no)	NO	NO	EXCEPTION TAKEN ON PURGE AIR RATE. SEE ATTACHMENT 2 FOR DETAILS.
Package Unit:		N/A	PER COMAIRCO E-MAIL OF 5/19/05.
Weight, lbs			FROM DRYER MFR'S DATA FOR MODEL TW1000.
Floor Space, sq ft			EXCEPTION TAKEN ON CAPACITY. SEE ATTACHMENT 2 FOR DETAILS.
B. INSTRUMENT AIR DRYER			PER COMAIRCO E-MAIL OF 5/11/05.
Manufacturer:	AIRTEK	HAD VISOR	
Model:	1000 TWP GREENS	EXTERNAL HEATED	
Type:	HEATED DESICCANT	900 CFM	
Size:	1000 SCFM @ 400 CFM 100 PSIG @ 100°F	2	
Flow Circuit of Dryer:		549	
Atmospheric:		DEMAND ON DEMAND	
Split Stream:		8 HR CYCLE	
Maximum Capacity @ given inlet conditions, SCFM	600		
Pounds of Water removed per cycle	455 FT/Min	3 1/2	
Linear Velocity thru bed, ft/min	4 Hr	12	
Absorption Cycle (Time), hrs	7.4 Hr	N/A	
Time Required for Reactivation	3.5 Hr	40	
Heating, hrs	5 MIN 25 MIN		
Cooling, hrs	7.4 HRS AVE.		
Power Required for Reactivation, kW	400°C		
Temperature required for Reactivation, °F	N/A		
Cooling Water Flow Rate, gpm	42		
Purge Air or Gas Flow Rate, SCFM			

SHT 7/9

Type and Quantity of Desiccant in each tower,  
Cross section area of desiccant bed, ft<sup>2</sup>  
Pressure drop through dryer @ maximum flow, psi  
Design Pressure, psig

Overall Dimensions/Weight of Unit

Height, inches

Width, inches

Length, inches

Weight (of complete unit), lbs

Headroom required to remove heater, inches

Connection Size/Rating

Gas

Cooling Water

Relief Valve Setting, psig

Remarks:

C. MIST ELIMINATORS

Manufacturer

Model No.

Dimension (O.D. x L), inches

Capacity, SCFM

Clean Pressure Drop, psi

Removal Efficiency

DP gage, (yes/no)

Type of Time Cycle Drain

COMAIRCO

ACTUATED ALUMINA

2.5 psi

150

96"

41"

74"

2350

N/A

150

SUGAR HANLISON (2)

MS600 MH3

17.75 x 4.4

600 500

0.5 PSI

99.98% to 100% microns  
99.98% to 0.1 μ

YES

TIMER

SCALES

ACTUATED ALUMINA

3

150

114

60

87

2400 #

See DWG

3" F

N/A

150

(1)

HANLISON

MH3

20 3/8"

500

LESS THAN 1

99.98% to 100% microns

YES

ELECTRIC

REMARKS

(1) PACKAGE WITH MOUNTED FILTERS, TOWER INSULATION, FAZ OPTION, DEW POINT MONITOR, 7 VALVE BY PASS.

(2) PER COMAIRCO E-MAIL OF 5/19/05.

(3) PER SCALES FAX OF 5/15/05.

(4) FROM HFR'S DATA.

	COMAIRCO	SCALES	REMARKS
D. AIR DRYER FILTERS			
Coalescing Prefilter			
Manufacturer	AIREK	HAWK1200	
Model No.	ST0600-C	HFS-54-24	
Capacity, SCFM	600	1000	
Clean Pressure Drop, psi	2	1	
Removal Efficiency	99.9% to 0.01 microns	99.5% to 0.1 microns	
DP gage, (yes/no)	YES	Yes	
Type of Time Cycle Drain	Timer	ELECTRIC	
Airfilter			
Manufacturer	AIREK	HAWK1200	
Model No.	ST0400F	HTA 1200	
Capacity, SCFM	664	1200	
Temperature Rating, ° F	450	450° F	
Clean Pressure Drop, psi	1	1	
Removal Efficiency	99.9% to 1 microns	99.5% to 1 microns	
DP gage, (yes/ no)	YES	Yes	

Date: May 18, 2005  
 By: J.Ferrero *JFF*

COVANTA LEE COUNTY  
 LEE COUNTY RESOURCE RECOVERY FACILITY  
 WASTE TO ENERGY EXPANSION PROJECT

**TECHNICAL BID EVALUATION  
 ATTACHMENT 4 – PRICING SUMMARY  
 RFP No. 2661-SM-126 - AIR COMPRESSORS**

	<u>COMAIRCO</u>	<u>SCALES</u>	<u>ATLAS</u> (Revised Bid)
<b>Base Price</b>	\$103,866.00 (1)	\$106,236.00 (1)	\$137,990.00 (2)
<b>Price Adjustments:</b>			
<u>Required Quoted Options:</u>			
Temperature gauge on dryer skid	(Incl. in Base Price)	\$400.00	(Incl. in Base Price)
Larger compressor size to meet capacity	(Not required)	\$17,100.00	(Not quoted) (3)
Combination motor starter/breaker	\$2,465.00	\$1,700.00	(Incl. in Base Price)
Larger dryer size to meet capacity	\$6,541.00	\$7,800.00 (5)	
Motor Mfr. as per Spec.	(Incl. in Base Price)	\$13,000.00	
<b>SUBTOTAL (Required Options)</b>	\$9,006.00	\$40,000.00	\$0.00
<u>Recommended Options:</u>			
Third Air Receiver	\$1,925.00	\$2,290.00	\$3,675.00
<b>TOTAL ADJUSTED EQUIPMENT COST (with required and recommended options)</b>	\$114,797.00	\$148,526.00	\$141,665.00 (2)
<u>Evaluated Costs:</u>			
Power Consumption (4)	\$10,198.00	\$0.00	
<b>TOTAL EQUIPMENT EVALUATED COST (with required and recommended options)</b>	\$124,995.00	\$148,526.00	
<u>Other Offered Options:</u>			
ASME Code coolers	\$11,549.00	(Not offered)	

- NOTES:** (1) Includes transportation cost, FOB delivered jobsite.  
 (2) Price shall be considered approximate since a full evaluation was not performed on this bidder; other costs may be applicable.  
 (3) The compressor offered in the revised Bid was undersized. The compressor offered with the original Bid was oversized and the total cost was approximately \$160,000.00.  
 (4) The evaluated cost for power has been assessed at \$3,642.00 per KW.

**Lindsey Sampson - Air Compressor/Bid Evaluation - Selection & Recommendation SM-126**

---

**From:** "Young,Peter" <pyoung@CovantaEnergy.com>  
**To:** <SAMPSOLJ@leegov.com>, "D'Amico,Don" <ddamico@roe.com>  
**Date:** 6/3/2005 12:06 PM  
**Subject:** Air Compressor/Bid Evaluation - Selection & Recommendation SM-126  
**CC:** "Stuhrke,Steve" <sstuhrke@roe.com>, "Dennis Iavarone" <diavarone@roe.com>, "Anacker,Dennis" <danacker@CovantaEnergy.com>, "Howard,Jody" <Jody\_Howard@CovantaEnergy.com>

---

Gentlemen,

Based on B&R's Air Compressor Bid Evaluation, dated May 20, 2005, received by Covanta on May 23, 2005, Covanta concurs with B&R's selection and recommendation to purchase the subject package from Comairco. The following comments are for your consideration and guidance:

1. Commercial Terms & Conditions – Vendor has accepted the RFP Services/Goods Purchase Conditions, therefore requiring no further negotiations by the County.
2. Price: Covanta concurs with B&R's recommended options/adjustments and Recommended Award Price of \$114,797.
3. Bond: Vendor quoted a bond for County's consideration. This is an equipment delivery only order, therefore County does not require a bond and is not included in the recommended award.
4. Payment Terms: 25% for drawings; 25% upon release to manufacturer (Feb. 2006); and 50% upon delivery to site.
5. Schedule: Delivery Date of May 15, 2006 is two weeks later than that required by Project's Master Project Schedule. **Don D'Amico is requested to have Vendor confirm a delivery date of May 1, 2006.**

B&R should proceed immediately in completing and submitting 1) a purchase order term sheet that reflects the final agreements and understandings to be incorporated into the purchase order, and 2) a conformed specification, with all data sheet data filled-in, for inclusion in the purchase order.

B&R's original and current schedule for issuing this PO is May 31, 2005 and June 28, 2005, respectively. **Covanta recommends that the County have this award approved by the BOCC no later than the June 28, 2005 BOCC Meeting to avoid the July BOCC recess.**

Peter



Lee County Resource Recovery Facility Expansion Project  
ATTACHMENT A (to equipment purchase orders)  
**TECHNICAL DOCUMENT REQUIREMENTS**

<u>Document</u>	<u>Electronic File in pdf form</u>	<u>Hard copies</u>	<u>Recipient</u>
Review Dwgs	1 *** 0 0		B&R Covanta DC*** Covanta FM County/Purchaser
Final Record Dwgs (Certified)  Additionally, Seller shall provide one (1) CD containing all Certified Drawings to Covanta's Facility Manager with a copy of the Transmittal to Covanta's Document Control Department. Such CD files shall allow a complete drawing to be printed without assembling layers.	1 1 1 1 1 0	1 1 1 1 0	B&R Covanta DC Covanta CM Covanta FM GC County/Purchaser
Draft Installation, Erection, O&M Manual for Review		1	B&R
Final Installation, Erection, O&M Manuals * (required 4 weeks prior to shipment) Additionally, Seller shall provide one (1) CD containing the O&M Manual (electronic file) to Covanta's Facility Manager with a copy of the Transmittal to Covanta's Document Control Department.		7 1 2 1 1 0	B&R Covanta DC Covanta CM Covanta FM GC County/Purchaser
Packing List – 4 weeks prior to shipment	1 0 1 0 1 1		B&R Covanta DC Covanta CM Covanta FM GC County/Purchaser
Spare Parts List submitted at the same time as Certified Drawings are submitted, complete with prices ** (in addition to those to be supplied w/ O&M Manuals)	1 1 1 3 0 0		B&R Covanta DC Covanta CM Covanta FM GC County/Purchaser

\* One print of each certified drawing and a priced spare parts list shall be included in the Operation & Maintenance Manual

\*\* Complete priced spare parts list is to be submitted for one (1) year of operation; prices firm for one (1) year.

\*\*\*A copy of Seller's/supplier's transmittal document only must be sent to Covanta's Document Control Department simultaneously with all technical documents submitted to others.

DC = Document Control

CM= Covanta's Construction Manager located at the jobsite (Facility site)

FM= Covanta's Facility Manager located at the Facility site

Lee County Resource Recovery Facility Expansion Project  
ATTACHMENT A (to equipment purchase orders)  
**TECHNICAL DOCUMENT REQUIREMENTS**

GC=General Contractor located at the jobsite (Facility site)

4/27/05