



Posted Date: April 19, 2024

Solicitation No.: B240252CJV

Solicitation Name: 500kW Trailer Replacement

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. QUESTIONS/ANSWERS

1.	Confirm if engine shall be EPA Tier 4 (Mobile Application) or EPA Tier 2 (Stationary Application).
Answer	Tier 4
2.	Confirm voltage required is 480VAC and that a selector switch is not required.
Answer	277/480V VAC no selector switch
3.	Confirm if a Transfer Switch (Manual or Automatic) is required. If so, please provide amperage and if it must be permanently installed on the trailer.
Answer	No transfer switch needed
4.	According to your specs only Cummins is the accepted product with no equals accepted, please by all means correct me if I am wrong.
Answer	Any manufacturer's product will be accepted if it meets the specifications listed in the bid document.
5.	In reference to solicitation B240252CJV, I saw the requirement of needing written approval if we are to use a subcontractor. What do you need from me in order to get this written approval?
Answer	Complete the Subcontractor form in the solicitation package and include with your bid. It will be reviewed by the department involved for approval/rejection.
6.	I just want to confirm that no installation is needed for this project?
Answer	This unit is a portable unit, and no installation will be required. It should be delivered to the County as a complete unit.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Christy VanAllen
 Procurement Analyst
 Direct Line: 239-533-8839