



**Procurement Management Department**  
**2115 Second Street, 1<sup>st</sup> Floor**  
**Fort Myers, FL 33901**  
**Main Line: (239) 533-8881**  
**Fax Line: (239) 485-8383**  
[www.leegov.com/procurement](http://www.leegov.com/procurement)

**Posted Date:** May 14, 2024

**Solicitation No.:** B240252CJV

**Solicitation Name:** 500kW Generator Replacement

**Subject:** Addendum Number 4

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

**1. QUESTIONS/ANSWERS**

1.	Within the solicitation it lists a startup. Do you need a load bank test, or is this a simple startup and it's just filling with DEF and diesel.
<b>Answer</b>	<b>A manufacturer's standard 4-hour load bank test is required, as specified in Article 3.02 Testing of the Revised Attachment A posted with Addendum 3.</b>

**BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.**

**ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.**

*Christy VanAllen*

---

Christy VanAllen, Procurement Analyst  
 Direct Line: 239-533-8839  
 Lee County Procurement Management