


SECTION

- ① WATER MAIN
- ② SANITARY SEWER MAIN

CROSSING

NOTE: IF LESS THAN 18" CLEARANCE
ENCASE WATER MAIN IN
STEEL CASING




PLAN


- ① WATER MAIN
- ② SANITARY SEWER MAIN

PARALLEL

NOTE: IF LESS THAN 10' CLEARANCE
ENCASE WATER MAIN IN
STEEL CASING



A-A

	LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	TITLE: WATER AND SEWER CROSSING	
<small>REVISION:</small> 6/27/24	<small>DETAIL NO:</small> G-08.dwg	

NOT TO SCALE