



X" LENGTH VARIES DEPENDING ON OBJECT BEING SUPPORTED
SEE TABLE THIS SHEET FOR DIMENSIONS A THRU H

PIPING SUPPORT

PIPING SUPPORT DIMENSIONS			
	FOR 3/4" & 1"	FOR 1-1/2" TO 3"	FOR 4" & LARGER
(A)	1/4" X 3" X 3"	1/4" X 3-1/4" X 3-1/4"	1/4" X 5" X 5"
(B)	1.0"	1.0"	1-1/2"
(C)	2.0"	2-1/2"	4"
(D)	1/4" X 6" X 6"	1/4" X 8" X 8"	1/4" X 10" X 10"
(E)	1/4" X 2" X 4"	1/2" X 2" X 4"	1/2" X 4" X 6"
(F)	3/4"	7/8"	1-1/4"
(G)	3/4"	7/8"	1-1/4"
(H)	1.0"	1.0"	1-1/2"

NOTE:

- HOT DIPPED GALVANIZED STEEL MAY BE USED IN PLACE OF STAINLESS STEEL.



LEE COUNTY
UTILITIES
ENGINEERING

1500 MONROE STREET
FORT MYERS, FLORIDA 33901

TITLE:

**PIPING
SUPPORT**

REVISION:

4/4/24

DETAIL NO:

G-11.dwg

NOT TO SCALE