


**ANCHOR PIPE**

**NOTES:**

1. CONNECTION TO EXISTING AC WATER LINE SHALL BE ACCOMPLISHED WITH DUCTILE IRON (MJ) FITTINGS, DR-18 PVC PIPING ("SPOOL PIECE") AND TRANSITION COUPLING(S) WITH STAINLESS STEEL FASTENERS (PIPING MUST BE RESTRAINED IN ALL DIRECTIONS). ALL CUTTING OF AC PIPING SHALL BE ACCOMPLISHED WITH WET CUTTING.
2. FOR PRODUCTS AND MATERIALS SEE THE PROJECT SPECIFICATIONS AND QUALIFIED PRODUCTS LIST.
3. CONTRACTOR SHALL INSTALL A TRACING WIRE ALONG THE TRANSITION COUPLING AND VALVES.
4. ADD TRACER WIRE PER LCU STANDARD DETAIL G-03.
5. CONCRETE TO EXTEND 6" PAST ALL TEE CONNECTIONS. PLASTIC SHEETING (VISQUEEN) WRAPPED AROUND FITTING.

**NOT TO SCALE**

	<b>LEE COUNTY UTILITIES ENGINEERING</b> <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	TITLE: <b>AC MAIN CONNECTION</b>	
REVISION: <b>3/20/24</b>	DETAIL NO: <b>G-14.dwg</b>	