

- (3) EXTENSION STEM IF TOP OF OPERATING NUT IS MORE THAN 30" BELOW FINISH GRADE
- (4) VALVE BOX (SEE VALVE INSTALLATION DETAIL G-02)
- (5.) OUTLET FOR TESTING
- (6.) MJ RESTRAINED
- (7.) MAIN SIZE VARIES
- (8) TAPPING VALVE (SEE VALVE INSTALLATION DETAIL G-02)
- 9 LCU APPROVED ALL STAINLESS STEEL PRESSURE RATED TAPPING SLEEVE. FOR SIZE ON SIZE TAPS A FLANGED TAPPING SLEEVE IS REQUIRED. SPRING LOADED TAPPING SLEEVE IS REQUIRED WHEN CONNECTING TO HDPE (SEE APPROVED MATERIAL LIST)
- (0) BRASS PLATE (SEE VALVE INSTALLATION DETAIL G-02)
- CAST IRON DROP COVER MARKED "WATER", "SEWER" OR "REUSE"
- (12) COMPACTED SUITABLE EARTH BACKFILL
- (13) 3/4" GRANULAR MATERIAL #57 STONE
- (4) 10 GAUGE DOUBLE INSULATED COPPER LOCATING WIRE (SEE LCU STANDARD DETAIL)
- (15) MIXED CONCRETE (3000 PSI)
- (6) CONCRETE MUST EXTEND 6" PAST ALL TEE CONNECTIONS AND BE BROUGHT TO VIRGIN GROUND. PLASTIC SHEETING (VISQUEEN) WRAPPED AROUND FITTING

