



WASTE WATER FORCE MAIN

- ①. LCU APPROVED JOINT RESTRAINT FOR P.V.C. M.J. PIPE AND FITTINGS PLACED IN ACCORDANCE WITH JOINT RESTRAINT SCHEDULE. (SEE DETAIL G-10)
- ②. CONFLICT PIPE
- ③. LCU APPROVED C-900 PVC DR 14
- ④. 18" MIN. UNLESS OTHERWISE APPROVED BY LCU
- ⑤. 45° MECHANICAL JOINT FITTING, TYPICAL
- ⑥. 10 GAUGE DOUBLE INSULATED COPPER WIRE (SEE LCU STANDARD DETAIL)

NOT TO SCALE

	LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	TITLE: WASTE WATER FM VERTICAL OFFSET WITH FITTINGS	
REVISION: 3/7/24	DETAIL NO: S-01.dwg	