


- ①. LCU APPROVED JOINT RESTRAINT FOR D.I., M.J. PIPE AND FITTINGS PLACED IN ACCORDANCE WITH JOINT RESTRAINT SCHEDULE (SEE DETAIL G-10).
- ②. CONFLICT PIPE
- ③. LCU APPROVED DUCTILE IRON PIPING PRESSURE CLASS 350
- ④. 18" MIN. UNLESS OTHERWISE APPROVED BY LCU
- ⑤. 45° MECHANICAL JOINT FITTING, TYPICAL
- ⑥. 10 GAUGE DOUBLE INSULATED COPPER WIRE (SEE LCU STANDARD DETAIL)

NOT TO SCALE

	LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	TITLE: WATER PRESSURE LINE VERTICAL OFFSET W/DIP & MJ FITTINGS	
REVISION: 2/27/24	DETAIL NO: W-01.dwg	