


- ① 45° MJ D.I.P. BEND
- ② TEMPORARY FLUSHING PIPE
- ③ END OF WATER MAIN
- ④ 24" MIN.

NOTES:

1. FLUSHING DETAIL TO BE USED ON WATER LINES 8" DIAMETER OR GREATER.
2. FLUSHING PIPE SHALL BE THE SAME DIAMETER AS WATER MAIN.
3. CONTRACTOR SHALL PROVIDE ADEQUATE DRAINAGE FOR FLUSHED WATER.
4. PROVIDE M.J. CAP IF ASSEMBLY IS LEFT IN PLACE UNATTENDED.
5. 10 GAUGE DOUBLE INSULATED COPPER LOCATING WIRE (SEE LCU STANDARD DETAIL)

**NOT TO SCALE**

	LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET          FORT MYERS, FLORIDA 33901</small>	
	<b>TITLE: WATER MAIN          FLUSHING DETAIL</b>	
REVISION: 2/27/24	DETAIL NO: W-02.dwg	