



- | | |
|---|--|
| ① FINISHED GRADE | ⑦ 2" - 90° BEND (BRASS) |
| ② 5'-0" MAX. | ⑧ M.J. CAP WITH 2" TAP |
| ③ WATER METER BOX W/GRAVEL BOTTOM
(SEE APPROVED MATERIAL LIST) | ⑨ END OF WATER MAIN, R.J. PER
SCHEDULE |
| ④ 2" THREADED PLUG (BRASS) | ⑩ 2" THREADED BRASS NIPPLE |
| ⑤ 2" - 45° BEND (BRASS) | ⑪ NOT USED |
| ⑥ 30" MIN." | ⑫ POURED IN PLACE THRUST BLOCKING
(SEE DETAIL X-XX) |
| | ⑬ 2" IRON BODY GATE VALVE, THREADED |
| | ⑭ 10 GAUGE DOUBLE INSULATED COPPER
LOCATING WIRE (SEE LCU STANDARD
DETAIL) |

NOTE:

ALL PIPING TO BE 2" THREADED FITTINGS OR SOLVENT



LEE COUNTY
UTILITIES
ENGINEERING
1500 MONROE STREET
FORT MYERS, FLORIDA 33901

TITLE:

**BLOW OFF
DETAIL**

REVISION:

2/27/24

DETAIL NO:

W-03.dwg

NOT TO SCALE