

END OF LCU MAINTENANCE
PROPERTY LINE
RIGHT OF WAY OR LIMIT OF EASEMENT


SECTION

- ①. 1 FT. MINIMUM - 2 FT. MAXIMUM, LOCATED IN P.U.E.
- ②. UTILITY BOX WITH COVER, TO BE LOCATED CLEAR OF DRIVEWAYS (SEE APPROVED MATERIALS LIST)
- ③. FINISHED GRADE
- ④. POLYETHYLENE TUBING, PE3408, 200 PSI, SDR9, BLUE (SEE APPROVED MATERIAL LIST)
- ⑤. STRAIGHT CURB STOP (SEE APPROVED MATERIAL LIST)
- ⑥. L.C.U. APPROVED DUAL CHECK BACKFLOW PREVENTER (SEE APPROVED MATERIAL LIST)
- ⑦. WATER METER BOX

NOTES:

- 1. INITIAL DEVICE TESTING REQUIRED. REFURBISH OR REPLACE DUAL CHECK BACKFLOW PREVENTER AT LEAST EVERY 5 TO 10 YEARS.

NOT TO SCALE

	LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	TITLE: 5/8" THROUGH 2" CROSS CONTROL ASSEMBLY	
REVISION: 3/1/24	DETAIL NO: W-07.dwg	