


NOTES:

- 1. UNIONS REQUIRED
- 2. INITIAL AND ANNUAL DEVICE TESTING REQUIRED

- ①. LCU APPROVED REDUCED PRESSURE BACKFLOW PREVENTION DEVICE (SEE APPROVED MATERIALS LIST)
- ②. FULL FLOW BRONZE BALL VALVE
- ③. UNION
- ④. ALL PIPING AND FITTINGS SHAL BE BRASS OR COPPER
- ⑤. 12" MIN. - 24" MAX. UNLESS OTHERWISE APPROVED BY LCU
- ⑥. FINISHED GRADE
- ⑦. METER BOX
- ⑧. 2' MAXIMUM

NOT TO SCALE

	LEE COUNTY UTILITIES ENGINEERING <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	TITLE: 3/4" TO 2" CROSS CONTROL ASSEMBLY	
<small>REVISION:</small> 3/1/24	<small>DETAIL NO:</small> W-08.dwg	