


**SIDE VIEW**

BRASS SERVICE SADDLES WITH CORPORATION STOP FOR PVC C-900 6" TO 12". ALL SIZES DUCTILE IRON PIPE SHOULD BE DIRECT TAP WITH CORPORATION STOP

**NOTE:**

- 1. 3' CLEARANCE ALL AROUND CONCRETE COLLAR

**NOT TO SCALE**

	<b>LEE COUNTY UTILITIES ENGINEERING</b> <small>1500 MONROE STREET FORT MYERS, FLORIDA 33901</small>	
	<b>TITLE: BACTERIA SAMPLE VALVE</b>	
<small>REVISION:</small> 3/20/24	<small>DETAIL NO:</small> W-14.dwg	